NO OBJECTION CERTIFICATE

NOC NO:25/2025

FIRE AND RESCUE STATION

DATE: 04.08.2025

TONDIARPET, CHENNAI-600081

FIRE & RESCUE STATION, TONDIARPET CHENNAI-600081.

Sub:

Fire and rescue service department Tondiarpet fire and rescue Station-Issue of NOC for constructed School Named Velammal Bodhi Campusregarding

Ref:

G.O.No.122 school education (2) Dept, Dt: 14.09.2014
G.O. No. 123 school education (2) Dept. Dt: 14.09.2014

Application received from the correspondent, Velammal Bodhi Campus, chennai- 81, Dt: 30.07.2025.

As per the G.Os referred above and the application M/S. VELAMMAL BODHI CAMPUS Constructed the Building Consist of Ground and four Floor's (G+4) With Height of 17.38 meters (Total Plot Area 2627.50 Sq. Mtr, Build up area 5102.06 Sq. Mtr) Located at N. No: 121, 123 & 125, OLD.NO: 25, 26 & 27, OLD VAITHIYANATHAN STREET, TONDIARPET, CHENNAI-600081, was inspected by the Station Officer Thiru P. ANJAPULI On 01.08.2025. No Objection Certificate is Granted for getting approval to ran the school from the Fire And Rescue Service Department Subject to the Following Conditions.

CONDITIONS

- Down Comer along with Hose Reel System to be provided with in 3 months.
- 2. 900 LPM Pump to be fixed with 25000 Liter Capacity of Over Head Water Tank.
- 3. Manually Operated Electronic Fire alarm System to be fixed in all floors.
- Fire Extinguisher Should be fixed in all floor's As Per Bureau of Indian Standards No. (IS): 2190: 2012.

OFFICE SEAL WITH DATE:

6 1000 00 100 100 100 1

To,

THE CORRESPONDENT,

M/S VELAMATAL BODHI CAMPUS,

N.No: 121,123 & 125, OLD.NO: 25,26 & 27,

OLD VAITHIYANATHAN STREET, TONDIARPET CHENNAI-600081.

Copy: District Officer North District.

Copy: License Issued officer.